

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 3225-0981:102

Page 1 of 2

CATEGORY: Fire Dampers

LISTEE: Greenheck Fan Corp., 400 Ross Ave., Schofield WI 54476-0410
Contact: *Marty Gissel (715) 692-6710 FAX (715) 355-3954

DESIGN: Models DFD-110, -150, -150X, -155; KFD-110, -150; FD-100, -110, -150, -150X, -155; SSDFD-150, -155, SSKFD-150, SSFD-150, -155; ODFD-110, -150, 150X, -155; OSSDFD-150, -155; OFD-100, -110, -150, -150X, -155 multi-blade curtain type fire dampers. Refer to listee's data sheet for additional detailed product description and operational considerations.

<u>Models</u>	<u>Single Section</u>		<u>Multiple Section</u>		<u>Installation</u>
	<u>W</u>	<u>H</u>	<u>W</u>	<u>H</u>	
FD-100	48"	48"	NA	NA	V
FD-110	48"	48"	96"	48"	V or H
FD-150, -155	48"	48"	120"	40"	V or H
			96"	48"	V or H
			74"	74"	V
FD-150X	48"	48"	120"	40"	V or H
			96"	48"	V or H
			96"	48"	V or H
DFD-110	36"	36"	96"	48"	V or H
DFD-150, -155	36"	36"	120"	40"	V or H
			96"	48"	V or H
			74"	74"	V
DFD-150X	36"	36"	120"	40"	V or H
			96"	48"	V or H
KFD-110	36"	16"	96"	48"	V or H
KFD-150	36"	16"	120"	40"	V or H
			96"	48"	V or H
SSFD-150, -155	48"	48"	120"	40"	V
			96"	48"	V
			36"	36"	NA NA H
SSKFD-150	36"	16"	120"	40"	V
			96"	48"	V

*Rev. 05-08-2002

SSDFD-150, -155	36"	36"	120"	40"	V
			96"	48"	V
	36"	36"	NA	NA	H
OFD-100,-110	36"	36"	NA	NA	V
OFD-150,-150X,-155	36"	36"	NA	NA	V
ODFD-110,-150,-150X,-155	36"	36"	NA	NA	V
OSSFD-150, -155	36"	36"	NA	NA	V
OSSDFD-150, -155	36"	36"	NA	NA	V

RATING: 1-1/2 Hour

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire dampers for use as described under "Design".

*Rev. 05-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division

